

HOWARD S. PANGBURN, President
 PAUL J. SCHATZEL, Secretary
 THOMAS M. DAVITT
 BENJAMIN SCHECTER
 ABRAM D. RELYEA

Kingston Water Department

CITY OF KINGSTON, N. Y.

OFFICE, CITY HALL

EDMUND T. CLOONAN, Superint.
 EDWIN L. WETTERHAHN,
 Cashier-Ast. Sec.
 FRED L. VAN DEUSEN, Senior Clerk

KINGSTON, N. Y. October 29, 1956

AC

Analysis:

Results in parts per million.

Color	None.
Turbidity	None.
Hardness	22.6
Alkalinity	9.0
Total solids	30.0
Loss on ignition	2.0
Silica SiO ₂	2.5
Aluminum Al	1.0
Sodium Na	0.4
Potassium K	1.0
Calcium Ca	8.0
Magnesium Mg	1.0
Iron Fe	0.1
Manganese Mn	none.
Chlorides Cl	4.0
Sulphate SO ₄	9.8
Carbonates CO ₃	1.0
Nitrates NO ₃	0.09
Hydrogen ion concentration pH	7.2

Newburgh

122.6

Leslie

400% Differential
 Dr. Wick

28.6

4.8

1.6

0.05

7.

Don't bel